



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.  
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

3 Tait Mews 10

Certificate No: Cert.2055

## Engineers Details

Trading Title: PLUMBANDHEAT.ME

Address: 132-134  
Great Ancoats Street  
Manchester  
Post Code: M4 6DE

Gas Safe No: 559973 Telephone No: 07929854373

## Installation Details

Installation Address: 3 Tait Mews Central Properties  
3 Tait Mews  
Heaton Mersey  
Stockport  
Post Code: SK4 3DX

Telephone No:

## Client Details

Client Address: Central Properties  
100 Birchfields Road  
Fallowfield  
Manchester  
Post Code: M146PH

Telephone No: 01612243044

## Appliance Details

## Inspection Details

	Location	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure (Mbar)	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	FlueType (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Combi boiler	Glowworm	Easicom 24	0.0002	0.0006	20.9 mb	56	YES	RS	YES	YES	YES	YES	PASS	NO	YES
2	Kitchen	Hob	Range	No Name	null	null	8.07 kw	0	YES	FL	YES	YES	YES	NA	NA	NO	YES
3	Lounge	Fire	Valor	Victorian Classic	0	0	19.5 mb		YES	OF	YES	YES	YES	YES	PASS	NO	YES
4																	
5																	

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: YES Gas Tightness Satisfactory: YES

Gas Installation Pipework Visual Inspection Satisfactory: YES

Number of Appliances Tested: 3 Equipotential Bonding: NO

NEXT INSPECTION DUE ON OR BEFORE: Fri-10-10-2025 Installation Pass: YES

CO Alarm fitted & working? YES Smoke alarm fitted & working? YES

## Signatures

Report Issued By:

Name: Robert Whiteoak

Report Received By:

Name:

Gas ID Number: 4959083

Signed:

Date: Tue-08-10-2024

Signed:

Date: Tue-08-10-2024